

**ASME B31.1-2014**  
(Revision of ASME B31.1-2012)

# Power Piping

**ASME Code for Pressure Piping, B31**

**AN INTERNATIONAL PIPING CODE®**



**The American Society of  
Mechanical Engineers**

Copyright © 2014 by the American Society of Mechanical Engineers.  
No reproduction may be made of this material without written consent of ASME.



INTENTIONALLY LEFT BLANK



**ASME B31.1-2014**  
**(Revision of ASME B31.1-2012)**

# Power Piping

---

**ASME Code for Pressure Piping, B31**

**AN INTERNATIONAL PIPING CODE®**



**The American Society of  
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Copyright © 2014 by the American Society of Mechanical Engineers.  
No reproduction may be made of this material without written consent of ASME.



Date of Issuance: August 15, 2014

The next edition of this Code is scheduled for publication in 2016. This Code will become effective 6 months after the Date of Issuance.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Interpretations, Code Cases, and errata are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org/> as they are issued. Interpretations and Code Cases are also included with each edition.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting “Errata” in the “Publication Information” section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,  
in an electronic retrieval system or otherwise,  
without the prior written permission of the publisher.

The American Society of Mechanical Engineers  
Two Park Avenue, New York, NY 10016-5990

Copyright © 2014 by  
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS  
All rights reserved  
Printed in U.S.A.



# CONTENTS

Foreword .....	vii	
Committee Roster .....	viii	
Introduction .....	xii	
Summary of Changes .....	xiv	
<b>Chapter I</b>	<b>Scope and Definitions</b> .....	1
100	General .....	1
<b>Chapter II</b>	<b>Design</b> .....	12
<b>Part 1</b>	<b>Conditions and Criteria</b> .....	12
101	Design Conditions .....	12
102	Design Criteria .....	13
<b>Part 2</b>	<b>Pressure Design of Piping Components</b> .....	19
103	Criteria for Pressure Design of Piping Components .....	19
104	Pressure Design of Components .....	19
<b>Part 3</b>	<b>Selection and Limitations of Piping Components</b> .....	34
105	Pipe .....	34
106	Fittings, Bends, and Intersections .....	34
107	Valves .....	35
108	Pipe Flanges, Blanks, Flange Facings, Gaskets, and Bolting .....	36
<b>Part 4</b>	<b>Selection and Limitations of Piping Joints</b> .....	37
110	Piping Joints .....	37
111	Welded Joints .....	37
112	Flanged Joints .....	38
113	Expanded or Rolled Joints .....	38
114	Threaded Joints .....	38
115	Flared, Flareless, and Compression Joints, and Unions .....	38
116	Bell End Joints .....	43
117	Brazed and Soldered Joints .....	43
118	Sleeve Coupled and Other Proprietary Joints .....	43
<b>Part 5</b>	<b>Expansion, Flexibility, and Pipe Supporting Element</b> .....	44
119	Expansion and Flexibility .....	44
120	Loads on Pipe Supporting Elements .....	46
121	Design of Pipe Supporting Elements .....	47
<b>Part 6</b>	<b>Systems</b> .....	50
122	Design Requirements Pertaining to Specific Piping Systems .....	50
<b>Chapter III</b>	<b>Materials</b> .....	66
123	General Requirements .....	66
124	Limitations on Materials .....	67
125	Creep Strength Enhanced Ferritic Materials .....	69
<b>Chapter IV</b>	<b>Dimensional Requirements</b> .....	71
126	Material Specifications and Standards for Standard and Nonstandard Piping Components .....	71
<b>Chapter V</b>	<b>Fabrication, Assembly, and Erection</b> .....	79
127	Welding .....	79
128	Brazing and Soldering .....	90
129	Bending and Forming .....	92
130	Requirements for Fabricating and Attaching Pipe Supports .....	93
131	Welding Preheat .....	95



132	Postweld Heat Treatment .....	95
133	Stamping .....	102
135	Assembly .....	102
<b>Chapter VI</b>	<b>Inspection, Examination, and Testing .....</b>	<b>104</b>
136	Inspection and Examination .....	104
137	Pressure Tests .....	108
<b>Chapter VII</b>	<b>Operation and Maintenance .....</b>	<b>111</b>
138	General .....	111
139	Operation and Maintenance Procedures .....	111
140	Condition Assessment of CPS .....	111
141	CPS Records .....	112
142	Piping and Pipe-Support Maintenance Program and Personnel Requirements .....	112
144	CPS Walkdowns .....	112
145	Material Degradation Mechanisms .....	112
146	Dynamic Loading .....	112
<b>Figures</b>		
100.1.2(A.1)	Code Jurisdictional Limits for Piping — An Example of Forced Flow Steam Generators With No Fixed Steam and Water Line .....	2
100.1.2(A.2)	Code Jurisdictional Limits for Piping — An Example of Steam Separator Type Forced Flow Steam Generators With No Fixed Steam and Water Line .....	3
100.1.2(B)	Code Jurisdictional Limits for Piping — Drum-Type Boilers .....	4
100.1.2(C)	Code Jurisdictional Limits for Piping — Spray-Type Desuperheater .....	5
102.4.5	Nomenclature for Pipe Bends .....	17
104.3.1(D)	Reinforcement of Branch Connections .....	24
104.3.1(G)	Reinforced Extruded Outlets .....	28
104.5.3	Types of Permanent Blanks .....	31
104.8.4	Cross Section Resultant Moment Loading .....	33
122.1.7(C)	Typical Globe Valves .....	55
122.4	Desuperheater Schematic Arrangement .....	59
127.3	Butt Welding of Piping Components With Internal Misalignment .....	80
127.4.2	Welding End Transition — Maximum Envelope .....	81
127.4.4(A)	Fillet Weld Size .....	84
127.4.4(B)	Welding Details for Slip-On and Socket-Welding Flanges; Some Acceptable Types of Flange Attachment Welds .....	85
127.4.4(C)	Minimum Welding Dimensions Required for Socket Welding Components Other Than Flanges .....	85
127.4.8(A)	Typical Welded Branch Connection Without Additional Reinforcement .....	85
127.4.8(B)	Typical Welded Branch Connection With Additional Reinforcement .....	85
127.4.8(C)	Typical Welded Angular Branch Connection Without Additional Reinforcement .....	85
127.4.8(D)	Some Acceptable Types of Welded Branch Attachment Details Showing Minimum Acceptable Welds .....	86
127.4.8(E)	Some Acceptable Details for Integrally Reinforced Outlet Fittings .....	87
127.4.8(F)	Typical Full Penetration Weld Branch Connections for NPS 3 and Smaller Half Couplings or Adapters .....	88
127.4.8(G)	Typical Partial Penetration Weld Branch Connection for NPS 2 and Smaller Fittings .....	89
135.5.3	Typical Threaded Joints Using Straight Threads .....	103



<b>Tables</b>		
102.4.3	Longitudinal Weld Joint Efficiency Factors .....	16
102.4.5	Bend Thinning Allowance .....	17
102.4.6(B.1.1)	Maximum Severity Level for Casting Thickness 4½ in. (114 mm) or Less .....	18
102.4.6(B.2.2)	Maximum Severity Level for Casting Thickness Greater Than 4½ in. (114 mm) .....	19
102.4.7	Weld Strength Reduction Factors to Be Applied When Calculating the Minimum Wall Thickness or Allowable Design Pressure of Components Fabricated With a Longitudinal Seam Fusion Weld .....	20
104.1.2(A)	Values of <i>y</i> .....	22
112	Piping Flange Bolting, Facing, and Gasket Requirements .....	39
114.2.1	Threaded Joints Limitations .....	43
121.5	Suggested Steel Pipe Support Spacing .....	48
121.7.2(A)	Carrying Capacity of Threaded ASTM A36, A575, and A576 Hot-Rolled Carbon Steel .....	49
122.2	Design Pressure for Blowoff/Blowdown Piping Downstream of BEP Valves .....	56
122.8.2(B)	Minimum Wall Thickness Requirements for Toxic Fluid Piping .....	63
126.1	Specifications and Standards .....	72
127.4.2	Reinforcement of Girth and Longitudinal Butt Welds .....	83
129.3.1	Approximate Lower Critical Temperatures .....	92
129.3.4.1	Post Cold-Forming Strain Limits and Heat-Treatment Requirements .....	94
131.4.1	Preheat Temperatures .....	96
132	Postweld Heat Treatment .....	97
132.1	Alternate Postweld Heat Treatment Requirements for Carbon and Low Alloy Steels, P-Nos. 1 and 3 .....	98
132.1.3	Postweld Heat Treatment of P36/F36 .....	98
132.2	Exemptions to Mandatory Postweld Heat Treatment .....	99
136.4	Mandatory Minimum Nondestructive Examinations for Pressure Welds or Welds to Pressure-Retaining Components .....	106
136.4.1	Weld Imperfections Indicated by Various Types of Examination .....	107
 <b>Mandatory Appendices</b>		
A	Allowable Stress Tables .....	113
	Table A-1, Carbon Steel .....	114
	Table A-2, Low and Intermediate Alloy Steel .....	126
	Table A-3, Stainless Steels .....	136
	Table A-4, Nickel and High Nickel Alloys .....	166
	Table A-5, Cast Iron .....	178
	Table A-6, Copper and Copper Alloys .....	180
	Table A-7, Aluminum and Aluminum Alloys .....	184
	Table A-8, Temperatures 1,200°F and Above .....	192
	Table A-9, Titanium and Titanium Alloys .....	198
	Table A-10, Bolts, Nuts, and Studs .....	202
B	Thermal Expansion Data .....	207
C	Moduli of Elasticity .....	216
D	Flexibility and Stress Intensification Factors .....	222
F	Referenced Standards .....	229
G	Nomenclature .....	233
H	Preparation of Technical Inquiries .....	240
J	Quality Control Requirements for Boiler External Piping (BEP) .....	241
N	Rules for Nonmetallic Piping and Piping Lined With Nonmetals .....	243



<b>Nonmandatory Appendices</b>		
II	Rules for the Design of Safety Valve Installations .....	271
IV	Corrosion Control for ASME B31.1 Power Piping Systems .....	293
V	Recommended Practice for Operation, Maintenance, and Modification of Power Piping Systems .....	297
VI	Approval of New Materials .....	310
VII	Procedures for the Design of Restrained Underground Piping .....	312
VIII	Guidelines for Determining If Low-Temperature Service Requirements Apply .....	323
<b>Index</b>	.....	333





# FOREWORD

The general philosophy underlying this Power Piping Code is to parallel those provisions of Section I, Power Boilers, of the ASME Boiler and Pressure Vessel Code, as they can be applied to power piping systems. The Allowable Stress Values for power piping are generally consistent with those assigned for power boilers. This Code is more conservative than some other piping codes, reflecting the need for long service life and maximum reliability in power plant installations.

The Power Piping Code as currently written does not differentiate among the design, fabrication, and erection requirements for critical and noncritical piping systems, except for certain stress calculations and mandatory nondestructive tests of welds for heavy wall, high temperature applications. The problem involved is to try to reach agreement on how to evaluate criticality, and to avoid the inference that noncritical systems do not require competence in design, fabrication, and erection. Someday such levels of quality may be definable, so that the need for the many different piping codes will be overcome.

There are many instances where the Code serves to warn a designer, fabricator, or erector against possible pitfalls; but the Code is not a handbook, and cannot substitute for education, experience, and sound engineering judgment.

Nonmandatory Appendices are included in the Code. Each contains information on a specific subject, and is maintained current with the Code. Although written in mandatory language, these Appendices are offered for application at the user's discretion.

The Code never intentionally puts a ceiling limit on conservatism. A designer is free to specify more rigid requirements as he feels they may be justified. Conversely, a designer who is capable of a more rigorous analysis than is specified in the Code may justify a less conservative design, and still satisfy the basic intent of the Code.

The Power Piping Committee strives to keep abreast of the current technological improvements in new materials, fabrication practices, and testing techniques; and endeavors to keep the Code updated to permit the use of acceptable new developments.



# ASME B31 COMMITTEE

## Code for Pressure Piping

(The following is the roster of the Committee at the time of approval of this Code.)

### STANDARDS COMMITTEE OFFICERS

**J. E. Meyer**, *Chair*  
**J. W. Frey**, *Vice Chair*  
**N. Lobo**, *Secretary*

### STANDARDS COMMITTEE PERSONNEL

<b>R. J. T. Appleby</b> , ExxonMobil Development Co.	<b>G. A. Jolly</b> , Flowserve/Gestra, USA
<b>C. Becht IV</b> , Becht Engineering Co.	<b>N. Lobo</b> , The American Society of Mechanical Engineers
<b>A. E. Beyer</b> , Fluor Enterprises	<b>W. J. Mauro</b> , American Electric Power
<b>K. C. Bodenhamer</b> , Willbros Professional Services	<b>J. E. Meyer</b> , Louis Perry & Associates, Inc.
<b>R. Bojarczuk</b> , ExxonMobil Research and Engineering Co.	<b>T. Monday</b> , Team Industries, Inc.
<b>C. J. Campbell</b> , Air Liquide	<b>G. R. Petru</b> , Enterprise Products
<b>J. S. Chin</b> , TransCanada Pipeline U.S.	<b>E. H. Rinaca</b> , Dominion Resources, Inc.
<b>D. D. Christian</b> , Victaulic	<b>M. J. Rosenfeld</b> , Kiefner/Applus RTD
<b>R. P. Deubler</b> , Fronex Power Systems, LLC	<b>J. T. Schmitz</b> , Southwest Gas Corp.
<b>W. H. Eskridge, Jr.</b> , Jacobs Engineering	<b>S. K. Sinha</b> , Lucius Pitkin, Inc.
<b>D. J. Fetzner</b> , BP Exploration Alaska, Inc.	<b>W. J. Sperko</b> , Sperko Engineering Services, Inc.
<b>P. D. Flenner</b> , Flenner Engineering Services	<b>J. P. Swezy, Jr.</b> , Boiler Code Tech, LLC
<b>J. W. Frey</b> , Stress Engineering Services, Inc.	<b>F. W. Tatar</b> , FM Global
<b>D. R. Frikken</b> , Becht Engineering Co.	<b>K. A. Vilminot</b> , Black & Veatch
<b>R. A. Grichuk</b> , Fluor Enterprises, Inc.	<b>G. A. Antaki</b> , <i>Ex-Officio</i> , Becht Engineering Co.
<b>R. W. Haupt</b> , Pressure Piping Engineering Associates, Inc.	<b>L. E. Hayden, Jr.</b> , <i>Ex-Officio</i> , Consultant
<b>B. P. Holbrook</b> , Babcock Power, Inc.	<b>A. J. Livingston</b> , <i>Ex-Officio</i> , Kinder Morgan

### B31.1 POWER PIPING SECTION COMMITTEE

<b>J. W. Frey</b> , <i>Chair</i> , Stress Engineering Services, Inc.	<b>B. P. Holbrook</b> , Babcock Power, Inc.
<b>W. J. Mauro</b> , <i>Vice Chair</i> , American Electric Power	<b>M. W. Johnson</b> , NRG Energy
<b>C. E. O'Brien</b> , <i>Secretary</i> , The American Society of Mechanical Engineers	<b>R. J. Kennedy</b> , DTE Energy
<b>D. D. Christian</b> , Victaulic	<b>D. J. Leininger</b> , WorleyParsons
<b>M. J. Cohn</b> , Intertek AIM	<b>W. M. Lundy</b> , U.S. Coast Guard
<b>D. H. Creates</b> , Ontario Power Generation, Inc.	<b>T. Monday</b> , Team Industries, Inc.
<b>S. D. Cross</b> , Golden Spread Electric Cooperative, Inc.	<b>M. L. Nayyar</b> , NICE
<b>G. J. Delude</b> , Penpower	<b>D. W. Raho</b> , CCM 2000
<b>R. P. Deubler</b> , Fronex Power Systems, LLC	<b>K. I. Rapkin</b> , FPL
<b>A. S. Drake</b> , Constellation Energy Group	<b>R. K. Reamey</b> , Turner Industries Group, LLC
<b>M. K. Engelkemier</b> , Stanley Consultants, Inc.	<b>E. H. Rinaca</b> , Dominion Resources, Inc.
<b>S. J. Findlan</b> , Shaw Power Group	<b>R. D. Schueler, Jr.</b> , The National Board of Boiler and Pressure Vessel Inspectors
<b>P. D. Flenner</b> , Flenner Engineering Services	<b>J. P. Scott</b> , Dominion
<b>E. C. Goodling, Jr.</b> , WorleyParsons	<b>J. J. Sekely</b> , Welding Services, Inc.
<b>J. W. Goodwin</b> , Southern Co.	<b>H. R. Simpson</b> , Stantec
<b>J. Hainsworth</b> , WR Metallurgical	<b>S. K. Sinha</b> , Lucius Pitkin, Inc.
<b>T. E. Hansen</b> , American Electric Power	<b>K. A. Vilminot</b> , Black & Veatch
<b>R. W. Haupt</b> , Pressure Piping Engineering Associates, Inc.	<b>A. L. Watkins</b> , First Energy Corp.
<b>C. L. Henley</b> , Black & Veatch Corp.	<b>H. A. Ainsworth</b> , <i>Contributing Member</i> , Consultant



### B31.1 SUBGROUP ON DESIGN

**K. A. Vilminot**, *Chair*, Black & Veatch  
**M. K. Engelkemier**, *Secretary*, Stanley Consultants, Inc.  
**M. J. Barcelona**, Riley Power, Inc.  
**S. M. Byda**, Power Engineers, Inc.  
**D. H. Creates**, Ontario Power Generation, Inc.  
**S. D. Cross**, Golden Spread Electric Cooperative, Inc.  
**A. S. Drake**, Constellation Energy Group  
**J. W. Goodwin**, Southern Co.  
**R. W. Haupt**, Pressure Piping Engineering Associates, Inc.  
**B. P. Holbrook**, Babcock Power, Inc.

**M. W. Johnson**, NRG Energy  
**R. J. Kennedy**, DTE Energy  
**W. M. Lundy**, U.S. Coast Guard  
**D. D. Pierce**, Puget Sound Naval Shipyard  
**K. I. Rapkin**, FPL  
**P. E. Sandage**, Sega, Inc.  
**T. Sato**, Japan Power Engineering and Inspection Corp.  
**D. B. Selman**, Middough, Inc.  
**A. L. Watkins**, First Energy Corp.  
**R. B. Wilson**, TWD Technologies Ltd.  
**A. D. Nance**, *Contributing Member*, Consultant

### B31.1 SUBGROUP ON FABRICATION AND EXAMINATION

**R. K. Reamey**, *Chair*, Turner Industries Group, LLC  
**R. B. Corbit**, Exelon Nuclear  
**R. D. Couch**, Electric Power Research Institute  
**P. M. Davis**, Foster Wheeler North America Corp.  
**C. Emslander**, Babcock & Wilcox  
**S. J. Findlan**, Shaw Power Group  
**P. D. Flenner**, Flenner Engineering Services  
**J. W. Frey**, Stress Engineering Services, Inc.  
**S. E. Gingrich**, URS Corp.

**J. Hainsworth**  
**T. E. Hansen**, American Electric Power  
**K. G. Kofford**, Idaho National Laboratory  
**S. L. Leach**, Babcock & Wilcox Construction Co., Inc.  
**D. J. Leininger**, WorleyParsons  
**T. Monday**, Team Industries, Inc.  
**J. J. Sekely**, Welding Services, Inc.  
**C. R. Zimpel**, Bendtec, Inc.  
**E. F. Gerwin**, *Honorary Member*

### B31.1 SUBGROUP ON GENERAL REQUIREMENTS

**W. J. Mauro**, *Chair*, American Electric Power  
**H. A. Ainsworth**, Consultant  
**R. D. Austin**, Arizona Department of Safety and Health  
**D. D. Christian**, Victaulic  
**G. J. Delude**, Penpower

**J. W. Power**, Alstom  
**R. D. Schueler, Jr.**, The National Board of Boiler and Pressure Vessel Inspectors  
**M. A. Treat**, Associated Electric Cooperative, Inc.  
**G. Trinker**, Victaulic Co.

### B31.1 SUBGROUP ON MATERIALS

**D. W. Rahoi**, *Chair*, CCM 2000  
**R. P. Deubler**, Fronex Power Systems, LLC  
**C. L. Henley**, Black & Veatch Corp.  
**S. L. McCracken**, Electric Power Research Institute

**L. C. McDonald**  
**M. L. Nayyar**, NICE  
**W. M. Sherman**, Swagelok Co.  
**N. S. Tambat**, Bechtel Corp.

### B31.1 SUBGROUP ON OPERATION AND MAINTENANCE

**R. J. Kennedy**, *Chair*, DTE Energy  
**M. K. Engelkemier**, *Secretary*, Stanley Consultants, Inc.  
**M. J. Barcelona**, Riley Power, Inc.  
**M. J. Cohn**, Intertek AIM  
**D. H. Creates**, Ontario Power Generation, Inc.  
**S. D. Cross**, Golden Spread Electric Cooperative, Inc.  
**P. M. Davis**, Foster Wheeler North America Corp.  
**S. DuChes**, Bechtel Power  
**P. D. Flenner**, Flenner Engineering Services  
**J. W. Frey**, Stress Engineering Services, Inc.  
**E. C. Goodling, Jr.**, WorleyParsons  
**J. W. Goodwin**, Southern Co.  
**T. E. Hansen**, American Electric Power

**R. W. Haupt**, Pressure Piping Engineering Associates, Inc.  
**B. P. Holbrook**, Babcock Power, Inc.  
**M. W. Johnson**, NRG Energy  
**W. J. Mauro**, American Electric Power  
**L. C. McDonald**  
**M. L. Nayyar**, NICE  
**K. I. Rapkin**, FPL  
**R. K. Reamey**, Turner Industries Group, LLC  
**E. H. Rinaca**, Dominion Resources, Inc.  
**J. P. Scott**, Dominion  
**L. Vetter**, Sargent & Lundy Engineers  
**A. L. Watkins**, First Energy Corp.



### B31.1 SUBGROUP ON SPECIAL ASSIGNMENTS

**S. K. Sinha**, *Chair*, Lucius Pitkin, Inc.  
**J. P. Scott**, *Secretary*, Dominion  
**M. J. Cohn**, Intertek AIM  
**S. DuChez**, Bechtel Power  
**E. C. Goodling, Jr.**, WorleyParsons

**E. H. Rinaca**, Dominion Resources, Inc.  
**H. R. Simpson**, Stantec  
**L. G. Vetter**, Sargent & Lundy Engineers  
**D. A. Yoder**, WorleyParsons

### B31 EXECUTIVE COMMITTEE

**J. W. Frey**, *Chair*, Stress Engineering Services, Inc.  
**N. Lobo**, *Secretary*, The American Society of Mechanical Engineers  
**G. A. Antaki**, Becht Engineering Co., Inc.  
**R. J. T. Appleby**, ExxonMobil Development Co.  
**D. D. Christian**, Victaulic  
**D. R. Frikken**, Becht Engineering Co.  
**R. A. Grichuk**, Fluor Enterprises, Inc.  
**L. E. Hayden, Jr.**, Consultant

**H. Kutz**, Johnson Controls Corp.  
**A. J. Livingston**, Kinder Morgan  
**J. E. Meyer**, Louis Perry & Associates, Inc.  
**M. L. Nayyar**, NICE  
**G. R. Petru**, Enterprise Products  
**S. K. Sinha**, Lucius Pitkin, Inc.  
**J. P. Swezy, Jr.**, Boiler Code Tech, LLC

### B31 CONFERENCE GROUP

**A. Bell**, Bonneville Power Administration  
**R. A. Coomes**, Commonwealth of Kentucky, Department of Housing/Boiler Section  
**D. H. Hanrath**  
**C. J. Harvey**, Alabama Public Service Commission  
**D. T. Jagger**, Ohio Department of Commerce  
**K. T. Lau**, Alberta Boilers Safety Association  
**R. G. Marini**, New Hampshire Public Utilities Commission  
**I. W. Mault**, Manitoba Department of Labour  
**A. W. Meiring**, Fire and Building Safety Division/Indiana  
**R. F. Mullaney**, Boiler and Pressure Vessel Safety Branch/Vancouver

**P. Sher**, State of Connecticut  
**M. E. Skarda**, Arkansas Department of Labor  
**D. A. Starr**, Nebraska Department of Labor  
**D. J. Stursma**, Iowa Utilities Board  
**R. P. Sullivan**, The National Board of Boiler and Pressure Vessel Inspectors  
**J. E. Troppman**, Division of Labor/State of Colorado Boiler Inspections  
**W. A. M. West**, Lighthouse Assistance, Inc.  
**T. F. Wickham**, Rhode Island Department of Labor

### B31 FABRICATION AND EXAMINATION COMMITTEE

**J. P. Swezy, Jr.**, *Chair*, Boiler Code Tech, LLC  
**F. Huang**, *Secretary*, The American Society of Mechanical Engineers  
**R. Campbell**, Bechtel National Inc.  
**R. D. Couch**, Electric Power Research Institute  
**R. J. Ferguson**, Metallurgist  
**P. D. Flenner**, Flenner Engineering Services  
**S. E. Gingrich**, URS Corp.

**J. Hainsworth**  
**A. D. Nalbandian**, Thielsch Engineering, Inc.  
**R. J. Silvia**, Process Engineers & Constructors, Inc.  
**W. J. Sperko**, Sperko Engineering Services, Inc.  
**P. L. Vaughan**, ONEOK Partners  
**K. Wu**, Stellar Energy Systems

### B31 MATERIALS TECHNICAL COMMITTEE

**R. A. Grichuk**, *Chair*, Fluor Enterprises, Inc.  
**N. Lobo**, *Secretary*, The American Society of Mechanical Engineers  
**W. P. Collins**, WPC Solutions, LLC  
**R. P. Deubler**, Fronex Power Systems, LLC  
**W. H. Eskridge, Jr.**, Jacobs Engineering  
**G. A. Jolly**, Flowserve/Gestra, USA  
**C. J. Melo**, S & B Engineers and Constructors, Ltd.

**M. L. Nayyar**, NICE  
**M. B. Pickell**, Willbros Engineers, Inc.  
**D. W. Raho**, CCM 2000  
**R. A. Schmidt**, Canadoil  
**H. R. Simpson**, Stantec  
**J. L. Smith**, Jacobs Engineering  
**Z. Djilali**, *Contributing Member*, Sonatrach

### B31.1 INTERNATIONAL WORKING GROUP – INDIA

**A. Kumar**, *Chair*, Bechtel India  
**G. Ravichandran**, *Vice Chair*, Bharat Heavy Electricals Ltd.  
**V. D. Bharani**, CH2M Hill  
**D. D. Christian**, Victaulic  
**R. Goel**, CB&I  
**N. Khera**, CH2M Hill India Pvt. Ltd.  
**T. Monani**, Foster Wheeler India  
**R. Muruganatham**, Larsen & Toubro Ltd.

**V. Pahujani**, Bechtel India Pvt. Ltd.  
**S. S. Palkar**, CH2M Hill India Pvt. Ltd.  
**P. P. Buddhadeo**, Bechtel India Pvt. Ltd.  
**P. Sanyal**, Bechtel India Pvt. Ltd.  
**R. P. Singh**, CB&I Lummus Private Ltd.  
**K. Srinivasan**, Bharat Heavy Electricals Ltd.  
**R. Tiwari**, CoDesign Engineering Pvt. Ltd.  
**M. Sharma**, *Contributing Member*, ASME



### B31 MECHANICAL DESIGN TECHNICAL COMMITTEE

- G. A. Antaki**, *Chair*, Becht Engineering Co., Inc.  
**J. C. Minichiello**, *Vice Chair*, Bechtel National, Inc.  
**R. Lucas**, *Secretary*, The American Society of Mechanical Engineers  
**D. Arnett**, Fluor Enterprises, Inc.  
**C. Becht IV**, Becht Engineering Co.  
**R. Bethea**, Newport News Shipbuilding  
**J. P. Breen**, Becht Engineering Co.  
**P. Cakir-Kavcar**, Bechtel Corp.  
**N. F. Consumo, Sr.**, Nuclear Engineer  
**J. P. Ellenberger**  
**D. J. Fetzner**, BP Exploration Alaska, Inc.  
**D. Fraser**, NASA Ames Research Center  
**J. A. Graziano**, Consultant  
**R. W. Haupt**, Pressure Piping Engineering Associates, Inc.
- B. P. Holbrook**, Babcock Power, Inc.  
**W. J. Koves**, Pi Engineering Software, Inc.  
**R. A. Leishear**, Savannah River National Laboratory  
**G. D. Mayers**, Alion Science & Technology  
**J. F. McCabe**, General Dynamics Electric Boat  
**T. Q. McCawley**, TQM Engineering  
**J. E. Meyer**, Louis Perry & Associates, Inc.  
**A. W. Paulin**, Paulin Research Group  
**R. A. Robleto**, KBR  
**M. J. Rosenfeld**, Kiefner/Applus RTD  
**T. Sato**, Japan Power Engineering and Inspection Corp.  
**G. Stevick**, Berkeley Engineering and Research, Inc.  
**H. Kosasayama**, *Delegate*, JGC Corp.  
**E. C. Rodabaugh**, *Honorary Member*, Consultant



# INTRODUCTION

The ASME B31 Code for Pressure Piping consists of a number of individually published Sections, each an American National Standard, under the direction of ASME Committee B31, Code for Pressure Piping.

Rules for each Section have been developed considering the need for application of specific requirements for various types of pressure piping. Applications considered for each Code Section include

- B31.1 Power Piping: piping typically found in electric power generating stations, in industrial and institutional plants, geothermal heating systems, and central and district heating and cooling systems
- B31.3 Process Piping: piping typically found in petroleum refineries; chemical, pharmaceutical, textile, paper, semiconductor, and cryogenic plants; and related processing plants and terminals
- B31.4 Pipeline Transportation Systems for Liquids and Slurries: piping transporting products that are predominately liquid between plants and terminals and within terminals, pumping, regulating, and metering stations
- B31.5 Refrigeration Piping and Heat Transfer Components: piping for refrigerants and secondary coolants
- B31.8 Gas Transmission and Distribution Piping Systems: piping transporting products that are predominately gas between sources and terminals, including compressor, regulating, and metering stations; and gas gathering pipelines
- B31.9 Building Services Piping: piping typically found in industrial, institutional, commercial, and public buildings, and in multi-unit residences, which does not require the range of sizes, pressures, and temperatures covered in B31.1
- B31.11<sup>1</sup> Slurry Transportation Piping Systems: piping transporting aqueous slurries between plants and terminals and within terminals, pumping, and regulating stations
- B31.12 Hydrogen Piping and Pipelines: piping in gaseous and liquid hydrogen service, and pipelines in gaseous hydrogen service

This is the B31.1 Power Piping Code Section. Hereafter, in this Introduction and in the text of this Code

<sup>1</sup> Incorporated into B31.4-2012.

Section B31.1, where the word *Code* is used without specific identification, it means this Code Section.

It is the owner's responsibility to select the Code Section that most nearly applies to a proposed piping installation. Factors to be considered by the owner include limitations of the Code Section, jurisdictional requirements, and the applicability of other codes and standards. All applicable requirements of the selected Code Section shall be met. For some installations, more than one Code Section may apply to different parts of the installation. The owner is also responsible for imposing requirements supplementary to those of the selected Code Section, if necessary, to assure safe piping for the proposed installation.

Certain piping within a facility may be subject to other codes and standards, including but not limited to

- ASME Boiler and Pressure Vessel Code, Section III: nuclear power piping
- ANSI Z223.1/NFPA 54 National Fuel Gas Code: piping for fuel gas from the point of delivery to the connection of each fuel utilization device
- NFPA Fire Protection Standards: fire protection systems using water, carbon dioxide, halon, foam, dry chemical, and wet chemicals
- NFPA 85 Boiler and Combustion Systems Hazards Code

– building and plumbing codes, as applicable, for potable hot and cold water, and for sewer and drain systems

The Code sets forth engineering requirements deemed necessary for safe design and construction of pressure piping. While safety is the basic consideration, this factor alone will not necessarily govern the final specifications for any piping system. The designer is cautioned that the Code is not a design handbook; it does not eliminate the need for the designer or for competent engineering judgment.

To the greatest possible extent, Code requirements for design are stated in terms of basic design principles and formulas. These are supplemented as necessary with specific requirements to ensure uniform application of principles and to guide selection and application of piping elements. The Code prohibits designs and practices known to be unsafe and contains warnings where caution, but not prohibition, is warranted.

The specific design requirements of the Code usually revolve around a simplified engineering approach to a subject. It is intended that a designer capable of applying more complete and rigorous analysis to special or unusual problems shall have latitude in the development of such designs and the evaluation of complex or

